

## FIN-001 INTERIM RESULTS 171114

### FIN-001 Awning Window - DG

ID	Name	Glazing Name	Glazing ID	U <sub>w</sub>	SHGC <sub>w</sub>	Tvis <sub>w</sub>
1	FIN-001-001-01-6SCAz-8Ar-4	6SCAz-8Ar-4	8338	2.3	0.13	0.13
2	FIN-001-002-01-638CPGy-8Ar-4	638CPGy-8Ar-4	8339	1.9	0.24	0.19
3	FIN-001-003-01-5-10Ar-4	5-10Ar-4	4690	2.3	0.40	0.43
4	FIN-001-004-01-6-8Ar-6ET	6-8Ar-6ET	10081	1.9	0.37	0.39
5	FIN-001-005-01-4-12Ar-4	4-12Ar-4	4781	2.3	0.41	0.43
6	FIN-001-006-01-4Gy-12Ar-4ET	4Gy-12Ar-4ET	10099	1.8	0.27	0.25
7	FIN-001-006-02-4-12Ar-4ET	4-12Ar-4ET	10101	1.8	0.39	0.40
8	FIN-001-007-01-5-10Ar-5	5-10Ar-5	4731	2.3	0.39	0.42
9	FIN-001-008-01-5Gy-10Ar-5ET	5Gy-10Ar-5ET	10056	1.8	0.24	0.21